

## Design Meeting Summary

MD Work Order #: RC100609.1223H.W04047

Date: 24 Feb 2016

Project/Task: Mechanical Design of Proton Detector

Submitted by: C. Wrede

Participants: P. Glennon, D. Lawton, J. Ottarson, D. Perez-Loureiro, C. Wrede

Issues discussed/results:

Design Consideration / Tasks – Patrick ...

- (1) For an aluminum chamber, 1/16 inch should be machined off all around the inside diameter after welding.
- (2) The entrance window needs to be sealed with an O-ring.
- (3) Sufficient room must be allowed for working with wrenches to make the VCO & VCR connections.
- (4) Standoffs for the aluminized mylar window are to be eliminated, and the window should somehow be attached to the PEEK structure used to support the field cage.
- (5) The degrader chamber should be a 4-way cross like that used in 7mdx88 & 7mdx99.
- (6) Some means of securing the field cage support structure in place inside the vacuum chamber needs to be added to the design.
- (7) Sufficient room must be allowed for the air-side SHV connectors on the upstream end.

Design Inputs Required – Chris / David ...

- (1) Can the proton detector vacuum chamber be made of stainless steel instead of aluminum?
- (2) Is it required that the gating grid be mounted off of the micromegas board instead of the field cage's PEEK support structure?
- (3) What is the maximum tolerable air gap between the kapton window and the proton detector's entrance window (1/16" thick aluminum)?
- (4) More details are needed regarding the physical make-up of the micromegas board and gating grid.